



le futur en construction

SAFETY, STRUCTURES AND FIRE DEPARTMENT

Reaction to Fire

REACTION TO FIRE CLASSIFICATION REPORT No. RA16-0111 ACCORDING TO THE EUROPEAN STANDARD NF EN 13501-1+A1:2013

Notification by the French Government to the European Commission under no. 0679

Seule la version française fait foi

The French version is legally acceptable

Product standard

NF EN 15102+A1:2011 "Decorative wall coverings - Roll and panel form products"

Owner:	RENOLIT ONDEX 57 Avenue de Tavaux 21800 CHEVIGNY-SAINT-SAUVEUR FRANCE
Commercial brand(s):	ONDEXPLAN
Manufacturing unit(s):	The manufacturing unit appears in the associated tests report
Brief description:	Decorative wall covering (see detailed description in paragraph 2)
Date of issue:	May 30th, 2016

This classification report certifies only the characteristics of the object submitted for testing but does not prejudice the characteristics of similar products. So it does not constitute a product certification in the sense of Articles L 115-27 to L 115-33 and R 115-1 to R 115-3 of the Consumer Code.

If this report is being issued by e-mail and/or on an electronic medium, only the hard copy of the report signed by CSTB shall prevail in the event of a dispute.

The reproduction of this classification report is only authorised in its integral form.

It comprises 5 pages.

CENTRE SCIENTIFIQUE ET TECHNIQUE DU BATIMENT

SIÈGE SOCIAL > 84 AVENUE JEAN JAURÈS | CHAMPS-SUR-MARNE | 77447 MARNE-LA-VALLÉE CEDEX 2

TÉL. (33) 01 64 68 84 12 | FAX. (33) 01 64 68 84 79 | www.cstb.fr

MARNE-LA-VALLÉE | PARIS | GRENOBLE | NANTES | SOPHIA-ANTIPOLIS

1. Introduction

This classification report defines the classification assigned to the above-mentioned product(s) in accordance with the procedures given in the NF EN 13501-1+A1:2013 standard.

2. Product description

Protective and decorative wall covering made of non-plasticized polyvinyl chloride (PVC) and fillers tested glued (acrylic glue applied at the rate of 300 g/m²) on A2-s1,d0 class paper-faced gypsum plasterboard substrate.

Nominal thickness: 2 mm.

Nominal weight per unit area: 2750 g/m².

Colours: various.

3. Tests reports and tests results in support of this classification

3.1 Tests reports

Name of laboratory	Name of sponsor	Test identification	Test report No.	Test method
CSTB	RENOLIT ONDEX 57 Avenue de Tavaux 21800 CHEVIGNY-SAINT-SAUVEUR FRANCE	ES541150462	RA16-0111	NF EN ISO 11925-2:2013 NF EN 13823+A1:2015

3.2 Tests results

Test method	Product	Number of tests	Parameters	Results
				Compliance parameters
NF EN ISO 11925-2 30s surface exposure	ONDEXPLAN	6	Fs > 150 mm Filter paper	Not reached Not ignited
NF EN ISO 11925-2 30s edge exposure	ONDEXPLAN	6	Fs > 150 mm Filter paper	Not reached Not ignited

Test method	Product	Number of tests	Parameters	Results	
				Continuous parameters Mean values	Compliance parameters
NF EN 13823+A1	ONDEXPLAN	3	FIGRA _{0.2MJ} (W/s)	83.4	-
			FIGRA _{0.4MJ} (W/s)	83.4	-
			LFS	-	Not reached
			THR _{600s} (MJ)	5.9	-
			SMOGRAM ² (m ² /s ²)	57.9	-
			TSP _{600s} (m ²)	268.2	-
			Flaming droplets or debris	-	None

(-) means: not applicable

4. Classification and direct field of application

4.1 Reference of the classification

This classification has been carried out in accordance with clauses 11.6, 11.9.4 and 11.10.1 of the NF EN 13501-1+A1:2013 standard.

4.2 Classification

Fire behaviour		Smoke production		Flaming droplets or debris
B	-	s3	,	d0

Classification: B - s3, d0

4.3 Field of application

This classification is valid for the following product parameters:

- The product described in paragraph 2.
- A nominal thickness of 2 mm.
- A nominal weight per unit area of 2750 kg/m².
- Various colours.

This classification is valid for the following end use conditions:

- The product glued (acrylic glue applied at the rate of 300 g/m²) on any A1 or A2-s1,d0 class substrate with a density ≥ 525 kg/m³.
- Without air gap.

5. Limitations

The present document does not represent type approval or certification of the product.

The classification assigned to the product in this report is appropriate to a declaration of performance by the manufacturer within the context of system 3 attestation of conformity and CE marking under the European Construction Products Regulation (regulation UE no. 305/2011). The manufacturer has made a declaration, which is held on file. This confirms that the products design requires no specific processes, procedures or stages (e.g. no addition of flame-retardants, limitation of organic content, or addition of fillers) that are aimed at enhancing the fire performance in order to obtain the classification achieved. As a consequence the manufacturer has concluded that system 3 attestation is appropriate.

The test laboratory has, therefore, played no part in sampling the product for the test, although it holds appropriate references, supplied by the manufacturer, to provide for traceability of the samples tested.

Champs-sur-Marne, May 30th, 2016

**The Technician
Responsible for the test**



Benoit FOREST

**The Head of Reaction to Fire
Unit**



Gildas CREACH

.....END OF THE CLASSIFICATION REPORT